



ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)

(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)

Recognised by MOEF & CC(Ministry of Environment Forest and Climate Change)

Website: www.itslab.in, Email: contact@itslab.in, itrlclab@gmail.com, info@itslab.in, itrlclab@gmail.com

+91 9911659800, 9305780312, 09958849764, 07210888634



Report Code: W-081223-03, Page- 1 of 2

TEST REPORT

Water Sample Analysis

Report Code: W-081223-03

Issue Date: 30/01/2024

ISSUED TO : M/s. THE MILLENIUM SCHOOL

Plot No.- 58/1, Sector- K. P 5, Greater Noida West, (U.P.), India

SAMPLING & ANALYSIS DATA

Sample Description	: Drinking Water
Sample Drawn On	: 29/01/2024
Sample Drawn By	: Mr. Amardeep (ITS Representative)
Sampling Plan & Procedure	: IS:3025(Part 1)
Sample Quantity	: 1.0 Liter in Pet Bottle & 500ml in Sterilized Glass Bottle
Sample Received On	: 29/01/2024
Analysis Duration	: 29/01/2024 to 30/01/2024

TEST RESULTS

Essential test as per IS:10500-2012

S. No.	Parameter	Test Method	Results	Units	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	pH	IS:3025(Part-11)	6.85	-	6.5 – 8.5	-
2.	Colour	IS:3025(Part-4)	<5.0	Hazen	5	15
3.	Turbidity	IS:3025(Part-10)	<1.0	NTU	1	5
4.	Total Hardness (as CaCO ₃)	IS:3025(Part-21)	28.0	mg/l	200	600
5.	Chloride(as Cl)	IS:3025(Part-32)	13.0	mg/l	250	1000
6.	Iron (as Fe)	IS:3025(Part-53)	<0.05	mg/l	1.0	-
7.	Total Dissolved Solid	IS:3025(Part-16)	92.0	mg/l	500	2000
8.	Alkalinity (as CaCO ₃)	IS: 3025 (P- 23)	17.0	mg/l	200	600
9.	Fluoride (as F)	IS: 3025 (P- 60)	<0.1	mg/l	1.0	1.5
10..	Aluminum (as Al)	IS: 3025 (P- 55)	<0.01	mg/l	0.03	0.2
11.	Zinc (as Zn)	IS: 3025 (P- 49)	<0.01	mg/l	5.0	15
12..	Lead (as Pb)	IS-3025(P-47)	<0.01	mg/l	0.01	No Relaxation
13.	Mercury (as Hg)	IS-3025(P-48)	<0.001	mg/l	0.001	No Relaxation
14.	Free Residual Chlorine	IS: 3025 (P-26)	<0.1	mg/l	0.2	1.0
15.	Arsenic (as As)	IS-302 (P-37)	<0.01	mg/l	0.01	0.05
16.	Magnesium (as Mg)	IS:3025 (P-46)	3.15	mg/l	30	100

Ruby

CHECKED BY



AUTHORIZED SIGNATORY

Terms & Conditions :

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to invoiced amount.



ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itrlclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

Report Code: W-081223- 03, Page- 2 of 2

SENSORY REQUIREMENT

RESULTS				
S.No.	Parameter	Test Method	Results	Required as per IS-10500:2018
1.	Odour	IS:3025(Part-5)	Agreeable	Should be agreeable
2.	Taste	IS:3025(Part-8)	Agreeable	Should be agreeable

MICROBIOLOGICAL REQUIREMENT

RESULTS				
S.No.	Parameter	Test Method	Results	Required as per IS-10500:2018
1.	<i>Escherichia coli</i>	IS-15185:2016	Absent	Absent/100ml
2.	<i>Coliform Bacteria</i>	IS-15185:2016	Absent	Absent/100ml

Remarks: Based on above tested parameter, Water sample meets as per IS-10500:2012 specification.
Hence water is fit for Drinking purpose.

Ruby
CHECKED BY

AUTHORIZED SIGNATORY

Terms & Conditions :

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to invoiced amount.



GREATER NOIDA INDUSTRIAL DEVELOPMENT AUTHORITY

Plot No. – 01, Sector Knowledge Park – IV, Greater Noida
Distt.-Gautam Budh Nagar (UP)

Letter Ref. No. : JAL/2024/23

Date: 30/01/2024

SAFE DRINKING WATER CERTIFICATE

It is certified that drinking water as per test report (attached) from ITS TESTING LABORATORY PVT. LTD., Noida in premises of **The Millennium School, HS-58/1, Knowledge Park-5, Greater Noida West** was found satisfactory. You are requested to ensure to above the condition throughout the norms by the Central/State/UP Govt.

This certificate is valid for one year from date of issue.

Senior Manager (JAL)

To,

The Principal
The Millennium School
HS-58/1, Sector- Knowledge Park-V,
Greater Noida (west),
Distt-G.B. Nagar(U.P.)



GREATER NOIDA INDUSTRIAL DEVELOPMENT AUTHORITY

Plot No. – 01, Sector Knowledge Park – IV, Greater Noida
Distt.-Gautam Budh Nagar (UP)

Ref.: H.D/2023/816

Date: 15/12/2023

SANITARY CONDITION CERTIFICATE

it is certified that an inspection team headed by under signed from **Health Department, GNIDA** inspected **The Millennium School, HS-58/1, Sector – Knowledge Park-V, Greater Noida (west), Distt-G.B. Nagar(U.P.)** premises has been found satisfactory during the inspection. You are requested to ensure the above conditions throughout the session as per the norms prescribed by the Central/State/ U.T Govt.

The above valid for a period of **One Year**.

Senior Manager (Health)

To,

Principal
The Millennium School
HS-58/1, Sector- Knowledge Park-V,
Greater Noida (west),
Distt-G.B. Nagar(U.P.)